

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013297
DATE: 07/14/2016
CERTIFICATION PROGRAM: Structural
COMPANY: American Openings
CODE: 1348-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Openings, Inc. 6885 E. Southpointe Road Tucson, AZ 85734	<p style="text-align: center;">Series "A210"</p> <p style="text-align: center;">Aluminum Single Hung Window</p> <p style="text-align: center;">Configuration: O/X Glazing: Insulating Glass (Annealed)</p> <p>Frame: W-1200mm(47.25") H-1810mm(71.25") Sash: W-1154mm(45.44") H-911mm(35.88") DLO: W-1103mm(43.44") H-829mm(32.63")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-11 AAMA/WDMA/CSA 101/LS.2/A440-08	<p style="text-align: center;">Class R-PG25 1200 x 1810 (47 x 71)-H</p> <p style="text-align: center;">Design Pressure: ± 1200 Pa (25 psf) Water Penetration Resistance Pressure: 260 Pa (5.43 psf)</p>

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-110-19050-4
 Expiration Date: May 31, 2020

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122