

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013853-R1
DATE: 09/30/2017
CERTIFICATION PROGRAM: Structural
COMPANY: American Openings
CODE: 1348-I
REVISION DATE: 10/11/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Openings, Inc. 6885 E. Southpointe Road Tucson, AZ 85734	<p style="text-align: center;">Series "A-2020"</p> <p style="text-align: center;">Aluminum Sliding Door</p> <p style="text-align: center;">Configuration: XO Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-1816mm(71.5") H-2032mm(80")</p> <p>Panel: W-921mm(36.25") H-1988mm(78.25")</p> <p>DLO: W-835mm(32.88") H-1905mm(75")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-11 AAMA/WDMA/CSA 101/LS.2/A440-08	Class R-PG20 1816 x 2032 (72 x 80)-SD Design Pressure: 958 Pa (20 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Pressure: 150 Pa (3.13 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19050-11
Expiration Date: July 31, 2020

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122